




November 16, 1995

Mr. Dean Haymore
 Storey County Building Official and
 Planning Administrator
 Storey County Building Dept.
 P. O. Box 526
 Virginia City, NV 89440

ELEVATION CERTIFICATION LOT #21
FINISH FLOOR ELEVATION
BY REGISTERED CIVIL ENGINEER

Based on a filed survey of Lot 21, Rainbow Bend Subdivision, located at 21 Avenue de la Couleurs, the highest existing pad grade has been determined to be 4356.2. This lot is located within Flood Zone AO (depth 1 foot) per FIRM Community Panel 320033 0030 C. Therefore, the minimum finish floor elevation shall be 4357.2. Final as-built floor elevation has been verified by Summit Engineering as 4357.29, which is higher than the minimum required.

Eugene F. Wenski
 Eugene F. Wenski, P.E.



11/16/95

RECEIVED

DATE: 11-16-95
 STOREY COUNTY BUILDING
 AND PLANNING DEPARTMENT

\\gene\elevcert.21