



Lot 200 in
RB is a
Cercle de la
Ceresse address.
Wrong street name
on Cert.

July 17, 1996

RECEIVED

Mr. Dean Haymore
Storey County Building Official and
Planning Administrator
Storey County Building Dept.
P. O. Box 526
Virginia City, NV 89440

DATE: 10-8-96
STOREY COUNTY BUILDING
AND PLANNING DEPARTMENT

**ELEVATION CERTIFICATION LOT #200
PROPOSED FINISH FLOOR ELEVATION
BY REGISTERED CIVIL ENGINEER**

Based on a field survey of Lot 200, Rainbow Bend Subdivision, located at 200 Avenue de la D'emerald, the highest existing pad grade has been determined to be 4352.6. This lot is located within Flood Zone AO (depth 1 foot) per FIRM Community Panel 320033 0030 C. Therefore, the minimum finish floor elevation shall be 4353.6. Final finish floor verification will be required prior to issuance of a Certificate of Occupancy.

Clinton G. Thiesse
Clinton G. Thiesse, P.E.

7/17/96

RECEIVED

DATE: _____
STOREY COUNTY BUILDING
AND PLANNING DEPARTMENT

lukstelevcert.200

5405 Mae Anne Avenue • Reno, Nevada 89523 • (702) 747-8550 FAX (702) 747-8559
3684 S. Highland Drive • Las Vegas, Nevada 89103 • (702) 252-3236 FAX (702) 252-3247
607 South Fifth Street • Elko, Nevada 89801 • (702) 738-8058 FAX (702) 738-8267